

JAMES E. RISCH – Governor RICHARD M. ARMSTRONG – Director DEBBY RANSOM, R.N., R.H.I.T - Chief BUREAU OF FACILITY STANDARDS 3232 Elder Street P.O. Box 83720 Boise, Idaho 83720-0036 PHONE: (208) 334-626 FAX: (208) 364-1888 E-mail: fsb@idhw.state.id.us

September 14, 2006

Linda Vestal, Administrator Guardian Angel Homes - Village Ops - Lewiston 2223 Vineyard Ave Lewiston, ID 83501

License #: RC-679

Dear Ms. Vestal:

On July 27, 2006, a life safety code survey was conducted at Guardian Angel Homes - Village Ops - Lewiston. As a result of that survey, deficient practices were found. The deficiencies were cited at the following level(s):

• Non-core issues, which are described on the Punch List, and for which you have submitted evidence of resolution.

This office is accepting your submitted evidence of resolution.

Should you have questions, please contact Eric Mundell, Health Facility Surveyor, Facility Fire, Life Safety, and Construction Program, at (208) 334-6626.

Sincerely

ERIC MUNDELL

Team Leader

Health Facility Surveyor

Facility Fire, Life Safety, and Construction Program

EM/slc

c:

Mark Grimes, Supervisor, Facility Fire, Life Safety, and Construction Program

JAMES E, RISCH – Governor RICHARD M. ARMSTRONG – Director DEBBY RANSOM, R.N., R.H.I.T - Chief BUREAU OF FACILITY STANDARDS 3232 Elder Street P.O. Box 83720 Boise, Idaho 83720-036 PHONE: (208) 334-6626 FAX: (208) 364-1888 E-mail: fsb@idhw.state.id.us

August 9, 2006

Linda Vestal, Administrator Guardian Angel Homes - Village Ops - Lewiston 2223 Vineyard Ave Lewiston, ID 83501

Dear Ms. Vestal:

On July 27, 2006, a Life Safety Code survey was conducted at Guardian Angel Homes - Village Ops - Lewiston. The facility was found to be providing a safe environment and safe, effective care to residents.

The enclosed form, stating no core issue deficiencies were cited during the survey, is for your records only and need not be returned.

Please bear in mind that non-core issue deficiencies were identified on the punch list, a copy of which was reviewed and left with you during the exit conference. The completed punch list form and accompanying proof of resolution (e.g., receipts, pictures, policy updates, etc.) are to be submitted to this office by August 26, 2006.

Should you have any questions about our visit, please contact me at (208) 334-6626.

Sincerely,

MARK GRIMES

Supervisor

Fire/Life Safety & Sanitation Program

MG/slc

Enclosure

FORM APPROVED Bureau of Facility Standards (X3) DATE SURVEY STATEMENT OF DEFICIENCIES (X1) PROVIDER/SUPPLIER/CLIA (X2) MULTIPLE CONSTRUCTION COMPLETED AND PLAN OF CORRECTION IDENTIFICATION NUMBER: A. BUILDING 01 - ENTIRE BUILDING B. WING 13R679 07/27/2006 STREET ADDRESS, CITY, STATE, ZIP CODE NAME OF PROVIDER OR SUPPLIER 2223 VINEYARD AVE **GUARDIAN ANGEL HOMES - VILLAGE OPS - L** LEWISTON, ID 83501 SUMMARY STATEMENT OF DEFICIENCIES PROVIDER'S PLAN OF CORRECTION (X4) ID PREFIX (X5) COMPLETE DATE (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE (EACH DEFICIENCY MUST BE PRECEEDED BY FULL PREFIX REGULATORY OR LSC IDENTIFYING INFORMATION) TAG TAG DEFICIENCY) R9999 R9999 Initial Comments The facility was found to be in substantial compliance with the fire and life safety standards of the Rules for Residential or Assisted Living Facilities in Idaho. No core deficiencies were cited during the standard fire/life safety survey conducted on July 27, 2006. The surveyor conducting the survey was: Eric Mundell REHS Team Leader Health Facility Surveyor Keith Barkow Health Facility Surveyor

Bureau of Facility Standards

TITLE

(X6) DATE



BUREAU OF FACILITY STANDARDS P.O. Box 83720 Boise, ID 83720-0036 (208) 334-6626 fax: (208) 364-1888 ASSISTED LIVING Non-Core Issues Punch List

Facility Name	Physical Address ···	Phone Number
GUARDIAN AMEI HOMES	2221 VINETARD AVE	208-743-6500
Administrator	City	ZIP Code
LINDA VESTAI	LEWISTAN, ID	23501
Survey Team Leader /	Survey Type	Survey Date
ERIC MUNDEIL / KEITH BARKON	FIRE + LIFESAFETY	Jul-127, 2006

-		TO THE DARLEY	11-000
NON-	CORE ISSUES	· ·	yes Nes
ITEM #	RULE#	DESCRIPTION	DATE RESOLVED
	IDAPA 16.03.	Fire and Lije Sofely Requirements: All pon fire alarm test in	8/28/06
	22.400	The Timber and Coffage buildings The observed and	lan
		posted procedure for silencing the alarm actually	
		I disabled the two systems; subsequently, for fine	
		alarm system could not be re-activated by pull	
		Station (manual actuation) The procedure essentially	
		cuts off the operation of the fire clarm systems.	
		B) Escutcheon plates were missing in SR #3 Croftsman	8/28/06
***************************************		building (law condition). The finher hour basement	
		haid 4 terentcheon plater musing from Sprinkler heals	
****		() Stair wells reading to be sements were obstructed	8/24/06
		In hover and storage along stops / she bez in stair-	
		Intel.	
2	16.03.22.415	Maintenance of System: 1/2 tinter Conjuntures at hand	8/24/06
		Unsking Sinks were 149 and 142 degrees in the	• (• (• •
	į.	Craftsman and Cuttage Anild in a verme tively.	
Λ΄	Required Date	Signature of Facility Representative	
/tug	art 27, 2006 (XX/MVesCel	